



EXTERIOR COLOR: #2445 GRAY CLOUD	LOAD CENTER: 125 A, M.L. 120/240 VAC, 1P
INTERIOR COLOR: #2445 GRAY CLOUD	NEMA 1 - SIEMENS E08ML1125AS
INSULATION: 1" (R~7)	LIGHT: 100 WATT INCAN. - M 14915K54
DOOR HDR: SS SCHLAGE CLASSROOM STYLE	FAN: 585 CFM - G 1HLA1
SS STRAP HINGES	SHUTTER: 10" X 10" - G 5C210
SS SPRING CUSHIONED CRASH STOP	HEATER: 1500 WATT - G 5ZK68 & G 5ZK72
ACCESSORIES: NONE	OUTLET: GFCI - LEVITON

1500 WATT HEATER WITH GFCI
OUTLET MOUNTED ABOVE

8"
GFCI

585 CFM EXHAUST FAN
WITH FRP HOOD

INTERNAL MOUNTING FLANGE

10" X 10" INTAKE SHUTTER
WITH INSECT SCREEN

125 A, NEMA 1, MAIN LUG
CIRCUIT BREAKER PANEL

LIGHT/FAN SWITCH

PLAN VIEW

100 WATT VAPOR-TIGHT
INCANDESCENT LIGHT

42" W X
48" H
EQUIPMENT
MOUNTING
PANEL

REAR ELEVATION

TRACOM
FIBERGLASS PRODUCTS

ONE-PIECE FRP BUILDING, 10'-0" W X 12'-0" D
X 9'-2" H, WITH STANDARD ACCESSORIES PACKAGE

DWG. NO. OPB-120-144-110-01

REV 0

1) ANCHOR BOLTS BY OTHERS

PROJECT STANDARD BUILDING SIZE

DATE 11/5/03