



EXTERIOR COLOR: #2445 GRAY CLOUD	LOAD CENTER: 125 A, ML, 120/240 VAC, 1P
INTERIOR COLOR: #2445 GRAY CLOUD	NEMA 1 - SIEMENS E08ML1125AS
INSULATION: 1" (R~7)	LIGHT: 100 WATT INCAN. - M 14915K54
DOOR HDR: SCHLAGE SS CLASSROOM STYLE	FAN: 238 CFM - G 4WT42
SS STRAP HINGES	SHUTTER: 10" X 10" - G 5C210
SS DOOR STOP CHAIN	HEATER: 1500 WATT - G 5ZK68 & G5ZK72
ACCESSORIES: NONE	OUTLET: GFCI - LEVITON

100 WATT VAPOR-TIGHT INCANDESCENT LIGHT

42" W X 48" H EQUIPMENT MOUNTING PANEL

1500 WATT HEATER WITH GFCI OUTLET MOUNTED ABOVE
238 CFM AXIAL EXHAUST FAN WITH VS HOOD

10" X 10" INTAKE SHUTTER WITH INSECT SCREEN
125 A, NEMA 1 MAIN LUG CIRCUIT BREAKER PANEL
INTERNAL MOUNTING FLANGE
LIGHT/FAN SWITCH

TRACOM
FIBERGLASS PRODUCTS

ONE-PIECE FRP BUILDING, 5'-0" W X 3'-0" D X 7'-6" H WITH STANDARD ACCESSORIES PACKAGE

DWG. NO. OPB-60-36-90-01 REV 0

PROJECT STANDARD BUILDING SIZE DATE 11/26/03

1) ANCHOR BOLTS BY OTHERS