



CUTTHROAT FLUME SPECIFICATION

SECTION 11203 CUTTHROAT FLUMES

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Cutthroat flumes.

1.2 RELATED SECTIONS

1.3 REFERENCES

- A. ASTM D 638 – Standard Test Method for Tensile Properties of Plastics.
- B. ASTM D 790 – Standard Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials.
- C. ASTM D 2583 – Test Method for Indentation Hardness of Rigid Plastics by Means of a Barcol Impressor.
- D. "Generalized Discharge Relations for Cutthroat Flumes." Journal of the Irrigation and Drainage Division, ASCE.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Test results of representative fiberglass reinforced plastic laminate.
- C. Shop Drawings: Show:
 - 1. Critical dimensions, jointing and connections, fasteners and anchors.
 - 2. Materials of construction.
 - 3. Sizes, spacing, and location of structural members, connections, attachments, openings, and fasteners.
- D. Samples: 8-inch square sample of representative fiberglass reinforced plastic laminate.
- E. Manufacturer's installation instructions.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store products indoors or in weather protected area until installation. Protect from construction traffic and damage.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. The product shall be manufactured by TRACOM, Inc.; 6575-A Industrial Way, Alpharetta, Georgia 30004; Toll-Free Voice (877) 435-8637, Toll-Free Fax (866) 435-8637, www.tracomfrp.com.
- B. Requests for substitution must be made in writing and received by the engineer's office a minimum of ten (10) business days before bid opening. Substitutions shall be made in accordance with the provisions of Section 01600.
- C. Substitutions: Manufacturers not pre-approved shall not be allowed.



- D. Warranty: Flumes shall be warranted to be free of defects in workmanship and materials for a period of two years from shipment.

2.2 CUTHROAT FLUMES

- A. Flume Type: Provide flumes of the following types:
 - 1. Size: _____ INCHES L x _____ INCHES W.
- B. Construction:
 - 1. One-piece construction.
 - 2. Two-piece construction for field assembly (by others), includes T-304 stainless steel connection hardware (**OPTIONAL**).
- C. Materials:
 - 1. Fiberglass reinforced plastic.
 - 2. Gloss inside surfaces, free of irregularities.
 - 3. Minimum 3/16 inch wall thickness.
 - 4. Minimum 30% glass by weight.
 - 5. Isophthalic polyester resin.
 - 6. Removable pultruded fiberglass bracing at top of flume with T-304 stainless steel hardware.
 - 7. 2 inch (minimum) top and end stiffening flanges.
 - 8. Molded-in stiffening ribs, maximum 12 inch center to center spacing.
 - 9. 15 mil Isophthalic U.V. resistant gel coat on all surfaces, white interior, grey exterior.
 - 10. Anchor clips, pre-drilled with a 3/4 inch hole, pultruded fiberglass construction.
 - 11. Tensile strength (ASTM D 638): 14,000 PSI.
 - 12. Flexural strength (ASTM D 790): 27,000 PSI.
 - 13. Flexural modulus (ASTM D 790): 1,000,000 PSI.
 - 14. Barcol hardness (ASTM D 2583): 50.

2.3 OPTIONS: (***select all that apply***)

- A. Stilling well:
 - 1. 2 inch coupling, for user-supplied stilling well.
 - 2. 8 inch diameter attached, with 2 inch opening.
 - 3. 8 inch diameter detached, with 2 inch coupling, interconnection tubing by others.
 - 4. 12 inch diameter attached, with 2 inch opening.
 - 5. 12 inch diameter detached, with 2 inch coupling, interconnection tubing by others.
- B. Laminated, high visibility staff gauge:
 - 1. Graduated in 1/10 foot and 1/100 foot increments.
 - 2. Graduated in 2mm increments.
- C. Ultrasonic mounting bracket:
 - 1. Fixed position stainless steel.
 - 2. Horizontally and vertically adjustable stainless steel.
- D. Removable T-316 stainless steel bubble tube, for 1/8 inch O.D. bubble line.
- E. Removable T-316 stainless steel sample tube, for 3/8 inch O.D. sample line.
- F. End Connections:
 - 1. Inlet and / or outlet flat 45 degree wingwalls.
- G. Removable stainless steel probe carrier (***specify length and O.D. of probe***).
- H. Submerged probe / area velocity probe cavity (***specify length and O.D. of probe***).
- I. Removable open cell fiberglass grating over the flume.
- J. Removable flat fiberglass cover with T-304 stainless steel bolt hardware over the flume.
- K. Chemical or temperature resistant service (***the standard flexible boots are PVC, ensure that either the chemical or temperature is compatible with PVC or that alternate end connects are provided***):
 - 1. Gel coat only.



2. Gel coat and resin (required for temperature service).
3. Maximum temperature: _____ ° F.
4. Chemical(s) and concentration(s): _____.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Verify that the flume dimensions are correct and project conditions are suitable for installation. Do not proceed with installation until condition deficiencies have been corrected.

3.2 INSTALLATION

- A. Install products in accordance with engineer's instructions, plans, blueprints, etc.
- B. Ensure that the product is installed plumb and that the floor is level.
- C. Set the flume at the elevation indicated on the engineer's drawings.
- D. Embed the flume in concrete; pour concrete in maximum 6 inch lifts; internally line and brace the flume as necessary to ensure bowing or distortion does not occur.
- E. For additional installation instructions refer to latest revision of document C-I.

3.3 ADJUST AND CLEAN

- A. Clean surfaces in accordance with the manufacturer's instructions.
- B. Remove trash and debris, and leave the site in a clean condition.

END OF SECTION

Document: C-S
Revision: 0
Date: 1-1-14
By: Matt Kazmier