

# TRAPEZOIDAL FLUME SPECIFICATION

# SECTION 11208 TRAPEZOIDAL FLUMES

#### PART 1 GENERAL

#### 1.1 SECTION INCLUDES

A. Trapezoidal flumes.

## 1.2 RELATED SECTIONS

## 1.3 REFERENCES

- A. ASTM D 638 Standard Test Method for Tensile Properties of Plastics.
- B. ASTM D 790 Standard Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials.
- C. ASTM D 2583 Test Method for Indentation Hardness of Rigid Plastics by Means of a Barcol Impressor.
- D. "Trapezoidal Flumes for Open-Channel Flow Measurement." <u>Transactions of The American Society</u> of Agricultural Engineers.

## 1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Test results of representative fiberglass reinforced plastic laminate.
- C. Shop Drawings: Show:
  - 1. Critical dimensions, jointing and connections, fasteners and anchors.
  - 2. Materials of construction.
  - 3. Sizes, spacing, and location of structural members, connections, attachments, openings, and fasteners.
- D. Samples: 8-inch square sample of representative fiberglass reinforced plastic laminate.
- E. Manufacturer's installation instructions.

# 1.5 DELIVERY, STORAGE, AND HANDLING

A. Store products indoors or in weather protected area until installation. Protect from construction traffic and damage.

#### PART 2 PRODUCTS

# 2.1 MANUFACTURER

- A. The product shall be manufactured by TRACOM, Inc.; 6575-A Industrial Way, Alpharetta, Georgia 30004; Toll-Free Voice (877) 435-8637, Toll-Free Fax (866) 435-8637, www.tracomfrp.com.
- B. Requests for substitution must be made in writing and received by the engineer's office a minimum of ten (10) business days before bid opening. Substitutions shall be made in accordance with the provisions of Section 01600.
- C. Substitutions: Manufacturers not pre-approved shall not be allowed.



D. Warranty: Flumes shall be warranted to be free of defects in workmanship and materials for a period of two years from shipment.

Z.Z I KAPEZUIDAL FLUME	2.2	TRAPEZOIDAL FLU	MES
------------------------	-----	-----------------	-----

A.	Flume Type:	Provide flumes of	the following types:
	1. Style:	, Size:	

- B. Construction:
  - 1. One-piece construction.
  - 2. Two-piece construction for field assembly (by others), includes T-304 stainless steel connection hardware *(OPTIONAL)*.
- C. Materials:
  - 1. Fiberglass reinforced plastic.
  - 2. Gloss inside surfaces, free of irregularities.
  - 3. Minimum 3/16 inch wall thickness.
  - 4. Minimum 30% glass by weight.
  - 5. Isophthalic polyester resin.
  - 6. Removable pultruded fiberglass bracing at top of flume with T-304 stainless steel hardware.
  - 7. 2 inch (minimum) top and end stiffening flanges.
  - 8. Molded-in stiffening ribs, maximum 12 inch center to center spacing.
  - 9. 15 mil Isophthalic U.V. resistant gel coat on all surfaces, white interior, grey exterior.
  - 10. Anchor clips drilled for 3/4 inch, pultruded fiberglass construction.
  - 11. Tensile strength (ASTM D 638):
     14,000 PSI.

     12. Flexural strength (ASTM D 790):
     27,000 PSI.

     13. Flexural modulus (ASTM D 790):
     1,000,000 PSI.
  - 1. Barcol hardness (ASTM D 2583): 50.

# 2.3 OPTIONS (select all that apply)

- A. Stilling well:
  - 1. 2 inch coupling, for user-supplied stilling well.
  - 2. 8 inch diameter attached, with 2 inch opening.
  - 3. 8 inch diameter detached, with 2 inch coupling, interconnection tubing by others.
  - 4. 12 inch diameter attached, with 2 inch opening.
  - 5. 12 inch diameter detached, with 2 inch coupling, interconnection tubing by others.
- B. Laminated, high visibility staff gauge:
  - 1. Graduated in 1/10 foot and 1/100 foot increments, direct read.
  - 2. Graduated in 1/10 foot, 1/100 foot, and GPM increments, direct read (Small-Extra Large 60 sizes only).
  - 3. Graduated in 2mm increments.
- C. Ultrasonic mounting bracket:
  - 1. Fixed position stainless steel.
  - 2. Horizontally and vertically adjustable stainless steel.
- D. Removable T-316 stainless steel bubble tube, for 1/8 inch O.D. bubble line.
- E. Removable T-316 stainless steel sample tube, for 3/8 inch O.D. sample line.
- F. End Connections:

1.	Inlet and / or outlet (specify standard or low-profile) (low profile available for Small –
	Extra Large 60 sizes only) end adapters with:

i.	inch inlet and	d / or outlet pipe	e stubs with flexible F	PVC boot(s) a	and stainless	steel
	bands to connect to	inch,	style piping.			
ii	inch	ctule inlet and	/ or outlot ANST 150	lh flat-faco f	iboralace flan	anc

- ii. \_\_\_\_\_ inch, \_\_\_\_\_ style inlet and / or outlet ANSI 150 lb. flat-face fiberglass flanges.
- 2. Inlet / or outlet 45 degree flat wingwalls.
- G. Removable stainless steel probe carrier (specify length and O.D. of probe).



- H. Submerged probe / area velocity probe cavity (specify length and O.D. of probe).
- I. Removable open cell fiberglass grating over the flume.
- J. Removable flat fiberglass cover with T-304 stainless steel bolt hardware over the flume.
- K. Chemical or temperature resistant service (the standard flexible boots are PVC, ensure that either the chemical or temperature is compatible with PVC or that alternate end connects are provided):
  - 1. Gel coat only.
  - 2. Gel coat and resin (required for temperature service).
  - 3. Maximum temperature: \_\_\_\_\_ ° F.
  - 4. Chemical(s) and concentration(s):

## PART 3 EXECUTION

## 3.1 EXAMINATION

A. Verify that the flume dimensions are correct and project conditions are suitable for installation. Do not proceed with installation until condition deficiencies have been corrected.

# 3.2 INSTALLATION

- A. Install products in accordance with engineer's instructions, plans, blueprints, etc.
- B. Ensure that the product is installed plumb and that the upstream floor is level.
- C. Set the flume at the elevation indicated on the engineer's drawings.
- D. Embed the flume in concrete; pour concrete in maximum 6 inch lifts; internally line and brace the flume as necessary to ensure bowing or distortion does not occur.
- E. For additional installation instructions refer to latest revision of document T-I.

## 3.3 ADJUST AND CLEAN

- A. Clean surfaces in accordance with the manufacturer's instructions.
- B. Remove trash and debris, and leave the site in a clean condition.

**END OF SECTION** 

Document: T-S
Revision: 0
Date: 1-1-14
By: Matt Kazmier